

WELL COMPLETION REPORT

5-20  
 Date(s) 5/17/95 County Hampshire Permit #: DW-14-08-95-026  
 Town: Augusta Area Name/Location Coon Co. Acres Lot 2  
 Well Owner: Claude Powell Address: P.O. Box 454  
 Telephone Number: 301-872-4102 Ridge Md 20680  
 Well Driller: Mark Smith Address: HC 86 Box 2-A  
 Telephone Number: 304-822-4784 Springfield WV 26763

WELL LOG

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
0-8	Clay Shale	240' 4" pvc. liner Type of Well: <u>home</u> Drilling Method: <u>Air-Hammer</u> Well Diameter: <u>6 1/8"</u> Casing O.D.: <u>6 5/8"</u> Well Depth: <u>245</u> Date Completed: <u>5/17/95</u> CASING: Length <u>55</u> Feet Height above ground <u>1</u> Feet <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Cast Iron Other _____ Type _____ SCREEN <input checked="" type="checkbox"/> None Installed Type _____ Diameter _____ Slot/Gauge _____ Length _____ Set Between _____ Ft. and _____ f
9-38	Brown Shale	
39-214	hard gray Rick	
215	Water	
216-245	hard gray shale	
	1500 Gph.	

PUMPING OR BAILING TEST

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	78		
Pumping Rate (GPM)	25		
Pumping Level (Ft Below Grade)	200		
Duration of Test (In Hours)	1		
Recovery Time to Static Level (In Hours)	1/2		

WELL HEAD

Pitless Adapter: Type, Make, Etc. \_\_\_\_\_  
 Well Cap: Type, Make, Etc. Standard  
 Well Seal: Type, Make, Etc. \_\_\_\_\_  
 Well Platform:  
 Length \_\_\_\_\_ Width \_\_\_\_\_ Thickness \_\_\_\_\_  
 Grouting:  Yes  No  
 All Public Water Supplies must be grouted. pressure

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

B. Mark Smith #001  
 Name Certification No.  
B.W. Smith Well Drilling  
 Registered Business Name  
Benjamin Mark Smith 5/17/95  
 Signed Date

REVISED 1-7-77

SEPTIC TANK INSPECTION FORM

Hampshire County Health Department Installation Permit No. ST-14-94-L30  
Name of Owner Claude H. Lowell

Address P.O. Box 454, Ridge, MD 20680

Property Address Coan County Acres Lot #2

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served house No. Water Closets       

Lot Size 5 acres sq. ft. Area suitable for sewage disposal installation        sq. ft.

Source of Water Supply proprietor well No. Lavatories       

No. Bedrooms 3 No. Showers or Tubs        No. Baths       

No. Garbage Grinders        No. Automatic Washers 1

SEPTIC TANK

Material precast Length        x Width        x Depth        =        cubic feet

Liquid Depth        ft. Liquid Capacity 1000 gal.

Distance to: Dwelling 10' + Water Supply 50' + Nearest Property Line       

SOIL ABSORPTION SYSTEM

Type Drain Line Material gravelles Trench Width 24 Inches

Trench Depth 24 Inches Total Absorption area in Trench Bottom 900 sq. ft.

Diameter of Drain Line 10 Inches Type Filter Media       

No. of Drain Lines 3 Depth Filter Media Under Drain Line        Inches

Length of Each Line 100, 100, 100, ft. Depth Filter Media Over Drain Line       

Distance of Disposal Field to: (a) Dwelling 30' +

(b) Water Supply 100' + (c) Nearest Property Line       

An inspection of the septic tank system described herein disclosed that said system (MEETS) DOES NOT MEET the minimum standards established by the West Virginia State Department of Health.

8-4-94  
Date

J. P. K...  
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.