

Miller Drilling Co.
 329 N. Main St.
 Templeton, CA 93465
 (805) 434-1888

Miller Drilling Co.

Contractors License No. 324634

PUMP TEST REPORT

Job#: 23346
 WELL OWNER: Estate of Carl Treise Pump Set: 94 ft Well #: 5 inch
 BILLING ADDRESS: c/o Kim & Terry Mathis Pump Size: 1 hp Well Depth: 103 ft
 PO Box 1492 Testing Method: existing pump
 San Luis Obispo, CA 93406 Perf Rec: 17-100
 trmath@earthlink.net APN: 070-351-032
 Standing Level Before Test: 23.71 ft LOCATION: 4555 Las Pilitas
 Santa Margarita, CA 93453

TESTING

TIME	PUMPING LEVEL	WATER CONDITION	WATER/BOWLS	GPM
8:45am	start	CLEAR NO ODOR		17.1
8:50am	42.49 ft	CLEAR NO ODOR		16.9
8:55am	46.39 ft	CLEAR NO ODOR		16.8
9:00am	48.24 ft	CLEAR NO ODOR		16.8
9:30am	58.10 ft	CLEAR NO ODOR		16.4
10:25am	59.74 ft	CLEAR NO ODOR		16.4
11:55am	78.83 ft	CLEAR NO ODOR		15.9
12:30pm	81.0 ft	CLEAR NO ODOR		16
12:40pm	81.5 ft	CLEAR NO ODOR		16.5

Notes: _____

STANDING LEVEL AFTER TEST: 59 ft (5 min)
 FINAL TEST RESULTS: Produced: 16.5 GPM for 4 hours on: 10/1/2020
 Test Run By: Chris, Alex