

Tracking# 592935

**Texas Department of Licensing and Regulation**

Attention Owner:  
Confidentiality Privilege Notice  
on reverse side of owner's copy.

Water Well Driller/Pump Installer Section  
P.O. Box 12157 Austin, Texas 78711 Toll free (800)803-9202 (512)334-5540  
Email address: [water.well@tdlr.texas.gov](mailto:water.well@tdlr.texas.gov) Web address: [www.tdlr.texas.gov](http://www.tdlr.texas.gov)

This form must be completed  
and filed with the department  
and owner **within 60 days**  
upon completion of the well.

**WELL REPORT**

**A. WELL IDENTIFICATION AND LOCATION DATA**

**1) OWNER**

Name: Don Spaulding Address: 492 FM 1589 City: Eagle Pass State: Tx Zip: 78852

**2) WELL LOCATION**

County: Real Physical Address: 1 mile North of City: Rio Frio State: Tx Zip: 78834

**3) Type of Work**

New Well  Reconditioning  Replacement  Deepening  Other  
**4) Proposed Use (check)**  Monitor  Environmental Soil Boring  Domestic  Industrial  Frac  
 Irrigation  Injection  Extraction  De-watering  Testwell  Rig Supply  Stock or Livestock  
 Other:  Public Supply --- If Public Supply, were plans approved?  Yes  No

**5) Drilling Date**

Started 12/14/21  
Completed 12/16/21

**6) Diameter of Hole**

Dia. (in)	From (ft)	To (ft)
13"	0	18
8"	18	690

**7) Drilling Method (check)**  Driven  Air Rotary  Mud Rotary

Bored  Air Hammer  Cable Tool  Jetted  Hollow stem Auger  
 Reverse Circulation  Other:

**8) Borehole Completion**  Open Hole  Straight Wall

Under-reamed  Filter Packed  Other  
 Filter packed interval from: \_\_\_\_\_ ft. to: \_\_\_\_\_ ft. Size: \_\_\_\_\_ Type \_\_\_\_\_

From (ft.)	To (ft.)	Description and color of formation material
0	1	TOPSOIL
1	21	Caliche
21	33	Tan & Gray L.S.
33	83	Gray L.S.
83	148	Gray L.S. w/ shale
148	152	Anhydrite
152	213	Gray spec. L.S.
213	220	Anhydrite
220	232	Gray spec. L.S.
232	409	Tan & Gray spec. L.S.
409	510	Tan & Gray L.S. w/ Flint

(Use reverse side of Well Owner's copy, if necessary)

**9) Casing, Blank Pipe, and Well Screen Data**

Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
4 1/2	N	SDR17	-2	650	
4 1/2	N	MFG SCREEN	650	690	.030

**10) Annular Seal Data:** i.e. (from 0 ft. to 100 ft. 15 sacks of cement)

from: 0 ft. to: 12 ft. 15 sacks of CEMENT  
 from: 12 ft. to: 590 ft. 17 sacks of BENTONITE  
 Method Used: POSPIS EX+ Sealed By: UWWS  
 Distance to septic field or other concentrated contamination: NA ft.  
 Distance to Septic Tank: NA ft. Distance to Property Line: 50 ft.  
 Method of Measurement: Measured Approved by Variance #: \_\_\_\_\_

**14) Plugged**  Well plugged within 48 hours

Casing left in well:		Cement/Bentonite placed in well:		#Sacks or Material used
From (ft)	To (ft)	From (ft)	To (ft)	

**15) Type Pump**

Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
 Depth to pump bowls, cylinder, jet etc., \_\_\_\_\_ ft.

**16) Water Test**

Type test:  Pump  Bailor  Jetted  Estimated  Other  
 Yield: 50 gpm with 0 ft. drawdown after 2 hrs.

**17) Water Quality**

Depth of Strata: 647-670 Was a chemical analysis made?  Yes  No. Did you knowingly penetrate a strata which contains injurious constituents?  Yes  No  
 If yes, Type of water \_\_\_\_\_  
 Check One:  Naturally poor-quality groundwater - type High TDS  Hydrocarbons (i.e. gas, oil, etc.)  Hazardous material/waste contamination encountered  
 Other (describe) \_\_\_\_\_

I certify that while drilling, deepening, or otherwise altering the above described well, injurious water or constituents was encountered and the landowner was informed that such well must be completed or plugged in such a manner as to avoid injury or pollution.

**18) Company & Individual's Name:** (type or print) Utopia Water Well Service Lic. No.: 59907  
 Address: P.O. Box 246 City: Utopia State: TX Zip: 78884

By signing this well report, you certify that you drilled or supervised the drilling of this well and that each and all of the statements herein are true and correct.

Signature: [Signature] Date: 12, 29, 21 Name: Jacob Calik  
 Licensed Driller/Pump Installer Unlicensed Assistant (printed)

- 510 - 533 / Tan & Gray l.s. w/ Flint & Anhydrite  
533 - 556 / Tan & Gray spec l.s. w/ Gray shale  
556 - 590 / Gray spec l.s. w/ Flint  
590 - 632 / Tan & Gray spec l.s.  
632 - 670 / Tan & Gray sandstone  
670 - 690 / Gray sandstone