

Attention Owner: Confidentiality Privilege Notice on reverse side of owner's copy.

Department of License and Reg.

Water Well Driller/Pump Installer Program

P.O. Box 12157 Austin, Texas 78711 (512)463-7880 FAX (512)463-8646

Toll free (800)803-9202

Email address: water.well@license.state.tx.us

This form must be completed and filed with the department and owner within 60 days upon completion of the well.

HGCD# 02-456

ORIGINAL

WELL REPORT

Name: Gordon Green, Address: 1775 Hermitville, City: Medina, State: Tx, Zip: 78055

County: Kerr, Physical Address: 129 Upper Turtle Creek Rd, City: Kerr, State: Tx, Zip: 78028

3) Type of Work: New Well, Proposed Use: Domestic, 5) NT

6) Drilling Date: Started 7/17/02, Completed 7/30/02, 7) Drilling Method: Air Rotary, Air Hammer

8) Borehole Completion: Open Hole, Log of hole with depths and lithology (0-3 dirt, 3-10.3 lime, etc.)

9) Cementing Data: Cementing from 633 ft to 310 ft, # of sacks used 45

13) Plugged: Well plugged within 48 hours, Casing left in well table

14) Type Pump: Turbine, Jet, Submersible, Cylinder

15) Water Test: Type test Pump, Yield: 25 gpm with 0 ft drawdown after hrs.

16) Water Quality: Did you knowingly penetrate a strata which contain undesirable constituents?

11) Water Level: Static level 500 ft below, Date 7/30/02, 12) Packers table

Company or individual's Name (type or print): Bollinger Drilling Co., Lic. No. SA639PW

Address: PO Box 550, City: Harper, State: Tx, Zip: 78031

Signature: Ken Bell, Date: 8/30/02

HEADWATERS GROUNDWATER CONSERVATION DISTRICT (HGCD)
Certified Statement of Well Completion

HGCD Well #: 02-456R

Owner: Green

POSTED
8/7/02 (2)

SECTION 1

LICENSED DRILLER: Roger Ballinger LICENSE #: 54639PW

GPS location: Latitude: 29 degrees 58 minutes 29 seconds Longitude: 99 degrees 12 minutes 49 seconds

Distance of new well from nearest: Property Line 80⁺ ft (N S E W); Road 75⁺ ft; Existing Septic Leach Field na ft; River, Stream or Lake na ft; Existing Water Well na ft; Livestock Enclosure na ft; Other Source of Contamination (cemetery, petroleum storage tank, pesticide mixing/loading, spray irrigation, etc.) na ft.

Depth of TDS reading: 650 TDS reading: 350

COPY

I hereby certify that this well was drilled by me (or under my supervision) and that this well was drilled and completed in accordance with District and State requirements and each and all of the statements herein are true.

7-7-02
Date

Roger Ballinger
Driller Signature

SECTION 2

LICENSED PUMP INSTALLER: Kerr Co. Pump LICENSE #: 4103I

Pump specifications: Date Installed: _____

Size: _____ Yield: 13 gpm with _____ ft.
HP: 3 hp drawdown after _____ hrs.
Depth setting: 609 ft below surface

I hereby certify that this well was equipped by me (or under my supervision); that water quality analysis reports were submitted to the District prior to production in accordance with District and State requirements; that I have installed a meter as applicable; and that each and all of the statements herein are true.

8-6-02
Date

[Signature]
Pump Installer Signature

RECEIVED
AUG 6 2002
H.G.C.D.



UPPER GUADALUPE RIVER AUTHORITY
ENVIRONMENTAL LABORATORY

Request for Analysis or Service

RESULTS TO: Kerr Country Pump
1150 Sidney Baker South
Kerrville, TX 78028
Phone: (830) 257-4107
Fax: (830) 792-4342

COPY

Point of Collection: Well Water Source: Well
Chlorinated: Yes No Date & Time of Collection 8/09/2002 @ 12:00 pm
Collected By: Jerry Delivered By: Jerry
Comments: Gordon Green - 02-456R

Analysis or Service

Standard Water Analysis

<u>Test</u>	<u>Method</u>	<u>Result</u>	<u>per volume of measure</u>
Total Hardness	SM 2340 C	393	mg/l
Iron	H 8008	0.2	mg/l
Sulfate	H 8051	99	mg/l
Nitrate	H 8171	<0.2	mg/l
Fluoride	H 8029	1.2	mg/l
Chloride	SM 4500 B	17	mg/l
pH	SM 4500-H B	7.4	std. units
Conductivity	SM 2510 B	886	umhos/cm
Total Dissolved Solids	SM 2540 C	576	mg/l
Total Coliform	TDH Approved Method	Absent	Absent/Present
<i>E. Coli</i> Bacteria	TDH Approved Method	Absent	Absent/Present

Log In Number: 49380

8/20/02

RECEIVED

AUG 30 2002

H.C.